



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
TECHNICAL SERVICES DIVISION

James R. Thompson Center · 100 West Randolph Street · Suite 4-600 · Chicago, Illinois 60601
 Phone: 312-814-8960 Fax: 312-814-3459 E-Mail: sfm.techservices@illinois.gov

APPLICATION for DISPENSING ABOVEGROUND STORAGE TANK INSTALLATION

Complete and file with site plans, 8½ x 11” only, to the above address

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: (Must be mailing address):

Name _____
 Street Address _____
 City _____ State _____ Zip _____
 Contact Person Phone _____
 Email Address: _____

(2) FACILITY - (Name and address where tanks are located):

Name _____
 Street Address _____
 City _____ State _____ Zip _____
 County _____
 Contact Person Phone _____
 Email Address: _____
 Fire Department: _____

(3) PERSON/COMPANY INSTALLING TANK(S): I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that all information submitted is true, accurate and complete.

Company Name _____ Address _____
 City _____ State _____ Zip _____
 Telephone # _____ Fax # _____ Email Address: _____
 Name of Authorized Representative _____ Title or Position _____
 Signature _____ Date _____

(4) DOES THIS FACILITY QUALIFY FOR DISPENSING FROM ABOVEGROUND STORAGE PER SECTION 180.20(a) OF TITLE 41 ILLINOIS ADMINISTRATIVE CODE?

Yes No

(5) IS THE INSTALLATION BEING MADE FOR NON-RETAIL DISPENSING OF FUEL INTO THE FUEL TANKS OF MOTOR VEHICLES OR PORTABLE CONTAINERS AT FACILITIES NOT OPEN TO THE GENERAL PUBLIC?

Yes No

(6) SITE STATUS – (Check all that apply): Installing Initial AST Relocating Existing AST at Site
 Replacing Existing AST Adding Additional AST at Existing AST Site

(7) GENERAL INFORMATION - Fill in the appropriate blanks for the AST system(s) that will be installed. Attach additional sheet(s) if more space is needed.

Tank Number	Capacity in Gallons (Max 2,500 gal)	Product to be Stored	Is the Tank New or Used N/U	Material of Construction of Tank	Material of Construction of Piping	Is an Emergency Vent Provided? Y/N	Is Secondary Containment Provided? Y/N	Is Tank Electrically Grounded? Y/N

(8) METHOD OF SECONDARY CONTAINMENT:

- Earthen Dike Double Walled Tank Steel Catch-Pan
 Concrete Dike Tank Vaulted in Concrete Other (explain below)

Explanation: _____

(9) WILL MARINA DISPENSERS BE IN DIKED/CONTAINED AREA?

- Yes No Facility is Not a Marina

(10) IS A NORMAL VENT PIPE PROVIDED WHICH IS A MINIMUM 1½-INCH IN DIAMETER AND A MINIMUM OF 4 FT ABOVE THE FILL PIPE?

- Yes No

(11) WILL TANK(S) BEAR THE LISTING LABEL OF UL OR ANOTHER NATIONAL TESTING LAB? (CHECK ALL THAT APPLY)

- UL 142, UL 2080, UL 2085 UL 2044 UL 2045

Other National Testing Lab _____

(12) IF TANK(S) DO NOT BEAR THE LISTING LABEL OF A RECOGNIZED LAB, TO WHAT SPECIFICATIONS ARE THEY CONSTRUCTED?

Explanation: _____

(13) IS THIS A FIRE-RATED TANK?

- Yes No

(14) WILL TANKS BE FABRICATED ON SITE (FIELD ERECTED) OR PRE-FABRICATED AT FACTORY?

- Fabricated On Site Pre-Fabricated at Factory

(15) ARE THE TANKS MARKED TO INCLUDE THE NAME OF THE PRODUCT THEY CONTAIN AND THE WORDS "FLAMMABLE-KEEP FIRE AND FLAME AWAY" IN 4-INCH LETTERS?

- Yes No

(16) WILL PUMPS BE SECURED AND LOCKED DURING ALL PERIODS OF NON-USE?

- Yes No

(17) ARE TANK(S), PUMPS AND PIPING:

(1) At least 30ft. from any adjacent buildings, combustible materials, bulk flammable or combustible liquid storage tanks, and LP-Gas tanks?

- Yes No No (Fire rated tank is being used)

(2) At least 30 ft. from any property line?

- Yes No No (Fire rated tank is being used)

(18) WILL ALL VEHICLES BEING FUELED FROM THE TANK(S) BE 30 FT FROM PROPERTY LINES, BUILDINGS AND BULK FLAMMABLE/COMBUSTIBLE LIQUID STORAGE TANKS AND LP-GAS TANKS?

- Yes No

(19) IS COLLISION PROTECTION PROVIDED FOR THE TANK(S)?

- Yes No: Method of protection: _____

(20) IS ALL ELECTRICAL WIRING WITHIN 30 FT OF THE TANK IN RIGID METAL CONDUIT?

- Yes No

(21) METHOD FIRE SUPPRESSION PROVIDED?

- Portable fire extinguishers (Minimum rating of 4A:60 BC) Foam Suppression System

OTHER (EXPLAIN): _____

MAKE SURE SITE PLANS IDENTIFY ALL TANKS, PIPING, BUILDINGS AND PROPERTY LINES WITH ALL SEPARATION DISTANCES SHALL BE IDENTIFIED. INSUFFICIENT INFORMATION OR ILLEGIBILITY IS CAUSE FOR RETURN OR DENIAL.